

EASTERN KENTUCKY UNIVERSITY
DIVISION OF PURCHASES & STORES
RICHMOND, KENTUCKY
EKU 12-10
Lancaster Wall Renovation

DATE: 11.05.09

ADDENDUM NO: 1 (One)

PLEASE NOTE THE FOLLOWING:

- 1. 6" long #4 Steel pin should be used @ 24" on center to tie existing concrete cap with new built wall, maximum 6" from each end of the cap. Steel pin should be inserted 2" into concrete cap.**
- 2. Contractor can split existing concrete cap if necessary at his/her own risk for workability while working in the section of new brick wall and need to be discussed prior to contract award.**

Offeror must acknowledge receipt of this and any addenda either with Bid or by separate letter. Acknowledgement must be received in the Office of the Division of Purchases, Room 213, Jones Building, Richmond, KY not later than 11.10.09 – 10:00 AM ET if by separate letter, the following information must be placed in the lower left hand corner of the envelope.

BID NUMBER: EKU-12-10

Receipt Acknowledged

DUE DATE: 11.10.09

(firm name)

DUE TIME: 10:00 AM ET

(signature)